

PUBLIC NOTICE

SURFACE WATER MONITORING, ROUTINE MAJOR

The **City of Zavalla**, PWS ID **TX0030030**, has violated the monitoring and reporting requirements set by the Texas Commission on Environmental Quality (TCEQ) in Title 30, Texas Administrative Code (30 TAC), Section 290, Subchapter F. Public water systems that treat surface water and/or ground water under the direct influence of surface water are required to submit monthly operating reports with operational data of the treatment, disinfection and quality of the water provided to their customers.

We failed to monitor and/or report the following constituents: **distribution disinfectant residual**.

These violations occurred in the monitoring period of September 2024.

Results of regular monitoring are an indicator of whether or not your drinking water is safe. We did not complete all monitoring and/or reporting for surface water constituents, and therefore TCEQ cannot be sure of the safety of your drinking water during that time.

We are taking the following actions to address this issue: The City is revising their monitoring plan to include more sample sites that are representative of the water system. Revising the monitoring plan will ensure that the daily disinfectant residual sample in distribution is taken when the system is operating.

Please share this information with all people who drink this water, especially those who may not have received this notice directly (i.e., people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

If you have questions regarding this matter, you may contact Pam Hooks at 936-897-3311.

Posted /Delivered on: November 25, 2024
